

FIRE SAFETY CERTIFICATE


Date: 14.07.2025

No. 131 / 2025

Certified that the HOLY ANGELS PUBLIC SCHOOL at New Survey No.68/1PT,61, Alagapuram Village, MG Road, Fairlands, Salem West Taluk, Salem District, Salem. 636 016 comprised of Ground Floor, First Floor and Second Floor Owned by HOLY ANGELS PUBLIC SCHOOL have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the officers concerned of Fire Service on 14.07.2025 in the presence of SR. JOYCY AUGUSTINE, The Principal and that the building is fit for occupancy up to classes X. With effect from 14.07.2025 for a period of Three years in accordance with rule and subject to compliance of specific conditions as appended:-

1. This certificate is valid for Three Years from the date of issue.
2. Fire protection devices shall be placed in (Generator room, Class room, Laboratory and Computer room) the wall or easy to handle as per provisions of National Building Code 2015 and Indian Standards.
3. Water Tanks should always be kept in full.
4. Mock drill should be conducted periodically.
5. Emergency exit signs should be kept in red colour that even glows in the dark.
6. First Aid Kit should be kept and used properly.
7. Do not accumulate waste materials in the School premises.
8. Cooking room should be separate from the School building and LPG gas cylinders should be used safely without leakage.

Issued on 14.07.2025 at Salem by Mr. P. Sivakumar, Assistant District Officer,
Salem Fire and Rescue Station.



To,

The Principal,
HOLY ANGELS PUBLIC SCHOOL,
Alagapuram Village, MG Road,
Fairlands, Salem West Taluk,
Salem District, Salem- 636 016

[Signature]
Assistant District Officer
Fire and Rescue Services
Salem - 636 001
Salem District